

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3550-0610:116 Page 1 of 1

**CATEGORY:** Door Closer/Holders/Releasing Devices

**LISTED:** Dorma Door Controls, PO Box AC, Reamstown PA 17567-0411  
Contact: Rick Loose (717) 336-3881

**DESIGN:** Series ITS 96, concealed within the door, self-closing type swinging door closer. This device incorporates a frame header mounted track arm assembly. This closer is intended for use with metal cover swinging type doors to return a swinging door closer to the closed position after the door has been opened.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as door closer for use with swinging type non rated and rated doors where permitted by code. For rated doors, the door may require special preparations to maintain fire rating since the unit is concealed within the door. The door preparations must be conducted in accordance with NFPA 80 and door manufacturers' installation instructions.

09-30-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**  
*Program Manager*